



HYDROCARBON FUELS

Sales Specification
Valid: 08/2009

KERO 1-K Fuel

Properties	Sales Specifications		Test Methods
	Minimum	Maximum	
Appearance	Bright and Clear (B&C)		ASTM D4176 Modified
Flash Point, °C (Tag Closed Cup)	38.0		ASTM D56 Modified

Anti-static grade available.

KERO 1-K Anti-Static Fuel contains 3 ppm of Stadis® 450 anti-static additive.

Notes:

KERO 1-K Fuel meets:

ASTM D3699-08 specification requirements.

KERO 1-K Anti-Static Fuel meets:

ASTM D-3699-08 specification requirements.

CAN/CGSB-3.3-99 specification requirements.

For more information, to request samples and/or to place orders, call: 1 (800) 663-4109

The user may forward, distribute, and/or photocopy this copyrighted document only if it is unaltered and complete. You may not copy this document to a Web site. This information relates only to the material designated and may not be valid for such material used in combination with any other materials or in any process. Typical values are representative of production, may vary over time and may not match the date of publication. All information, to the best of our knowledge and belief, is accurate and reliable as of the date compiled. Moreover, no warranty or guarantee is made as to its accuracy, reliability or completeness nor do we offer any warranty against patent infringement. It is the user's responsibility to satisfy himself as to the suitability and completeness of such information for his own particular use. Sampling and testing procedures in effect at the time of production will be used for certification testing. Results may be based on tank certification, manufacturing data, periodic testing, compliance testing, shipment, end of run, rundown tank or most recent restock analysis. We reserve the right to use other test methods in certifying this material.